

The Principal

Bibi Kaulan Ji public school
Tarn Tarn Road Amritsar
District: Amritsar

No. 1897

Dated:- 15/10/2020

Subject:- Building safety certificate for the year 01-04-2020 to 31-03-2021 .

Ref:- Your letter No. 2513 Dated 5-10-2020

The Sub Divisional Engineer, Central Works Sub Division Batala at Amritsar

vide his letter No 327 Dated 13-10-20 has reported this office that the building of

Bibi Kaulan Ji public school Tarn


Tarn Road in District Amritsar has been visually inspected

and found the same provisionally fit for human inhabitation for the year 20-21 i.e.

upto 31-03-2021. Your application for safety certificate will only be considered when you

will fulfill all the requirement under column 14 of Proforma Part-I.

DA/Proforma I & II



Executive Engineer,
Central Works Divn No. 2,
PWD B&R Br, Amritsar.

Endst.No.

Dated:-

Copy to the Sub Divisional Engineer, Central Works Sub Division Batala at

Amritsar for information and necessary action w.r.t. his letter No. 327 Dated 13-10-20


Self
Executive Engineer,
Central Works Divn No. 2,
PWD B&R Br, Amritsar.

0 216

204

203

206

205

207

OPPO Reno2

PROFORMA FOR THE SAFETY CERTIFICATE OF SCHOOL BUILDING (PART-I)

(To be filled in by the head of school, institute)

- 1. Name of the School Bibi Kaulangi public school
- 2. Location Tern Tern Road Amritsar
- 3. Plot Area 23259.56 sqft
- 4. Covered Area of Building 49108.36 sqft
- 5. Number of Stories Four stories
- 6. Year of Construction 2008
- a) Frame Structure Frame structure
- b) Brick masonry structure

7. If the building has been constructed under the supervision of the qualified Engineer, the following details may be given:-

- a) Name of Engineer with qualification Sukhmander Singh Civil Engg.
- b) Address of the Engineer S/O-123, 5th floor Shopping complex B-Block Ranjit Avenue ABR
- c) If structural drawing used in the construction, if available? yes
- d) Name and address of Architect with qualification As Above

- 8. Whether the building has been constructed for the purpose of
 - a) School
 - b) Residential purpose and used for a school

Yes/No
Yes/No

- 9. Materials used for Roofs
 - a) R.C.C.Slabs
 - b) R.S.Joists & Battons
 - c) Wooden Joints and bottom

R.C.C. Slab.

- 10. Material used for Walls
 - a) Mud Mortor
 - b) Cement Motor
 - c) Lime Mortor

Yes/No
Yes/No
Yes/No

- 11. Flooring
 - a) Conglomerate
 - b) Terrace
 - c) Brick Paving

Yes/No
Yes/No
Yes/No

12. A detailed drawing indicating the doors alongwith windows and location fitting and windows is attached.

13. FOR FIRE SAFETY

- a) Whether the width of the staircase is 1.5 mtr.
- b) Whether portable fire extinguisher exists
- c) Whether School building is free from inflammable & toxic material
- d) Whether cooking of food is done at a safe place
- e) Whether any Thatch or combustible material has bee used

Yes/No
Yes/No
Yes/No
Yes/No
Yes/No ✓

14. Requirement for Fire Protection Arrangements under NB-Part-IV (For Building height less than 15 metre)

- a) Whether Hose Real provided Yes/No
- b) Whether down comer provided Yes/No
- c) Whether Automatic sprinkler provided Yes/No
- d) Whether underground static water storage tank of capacity 50000 Ltr.(if converted area exceeds 1500 sqm) Yes/No
- e) Whether over head tank of capacity 10000 Ltr.exists (in case of hose real) 20000 Ltr. Yes/No
- f) Whether one eclectic and one diesel pump of 3 kg/cum Pressure of capacity 1620 LPM, one electric pump of Capacity 180 LPK exist near underground static tank. Yes/No
- g) Whether a pump 3 kg/cum pressure & 450/500 LPM Exist near over head tank. Yes/No

Jasleen Kaur
Principal,
Zilli Kaulan Ji Public School,
Tarn Taran Road, Amritsar
Signature of the Head of School/
Institute

PART-II

(To be filled by the SDE of PWD (B&R) Department)

- a) I have visited the above mentioned school on dated 8-10-20 and have visually inspected it from all angles of safety and find it fit for normal use as school building.
- b) In case any addition/alteration or expansion and modifications to this buildings is to be carried out, the same be carried out under the supervision of a qualified Engineer and this certificate may be reobtained after the completion from the undersigned.
- c) In case the building is affected by flood, or if there is settlement of walls/ foundations or sagging of roofs etc. immediate inspection of the undersigned be arranged to check the stability and safety of the building.
- d) This building can be safely occupied for normal use upto (indicate upto which it can be used) 31-3-2021

[Signature]
Sub Divisional Engineer,
Central Waorks Sub Divn,
PWD, B & R Batala at ASR.

[Signature]